



ALTURA

Start with Haystack

An Owners Guide to Interoperability

Matt Schwartz, P.E.



Agenda

- Haystack Refresh
- Haystack in action
- Haystack in action
- Haystack in action
- Haystack in action
- Haystack in action
- Q&A


Haystack

Quick Refresh

Raw Asset Data



Portable, Scalable Utilization Reports Ex 1



Occupancy Data, meet Haystack

Occupancy Status – Occupied/Unoccupied



Occupancy Status – Occupied/Unoccupied



Occupancy Status – Occupied/Unoccupied



Occupancy Status – Occupied/Unoccupied





Tag Based Computation

 Occupancy Report Data Visualization


Select ▼ Select ▼ < 7-May-2019 > 8AM ⬆️ 5PM ⬆️ Percentage ⬆️

Occupancy Data	Total Space Count	Back Of House	Conf	Lab	Office
① Space Count	47	3	2	10	32
① Average Occupancy	55%	39%	77%	59%	42%
① Peak Occupancy	74%	67%	100%	90%	54%
① Peak Occupancy Time	2PM	2PM	11AM	5PM	2PM
① Lowest Occupancy	22%	33%	27%	15%	15%
① Lowest Occupancy Time	8AM	8AM	8AM	8AM	8AM

Portable, Multi-System, Space Utilization Reports



Haystack enabled API relationship Ex 2



How analytics become action

Sites ▾ Projects ▾ Open ▾ Any Status ▾ Owner ▾

Select Issue ▶ New Edit Dup Trash

Selected	Issue ID	Issue Name	Site	Related Equip
<input type="radio"/>	39	CX-M005 ExhSys-EF6 Static pressure (EF-6)	Mead	Mead EF-6
<input type="radio"/>	40	Firestone AHU-2 Bldg Static Spark Request	Firestone	Firestone AHU-2
<input type="radio"/>	41	CX-F007 VAV-376 Clarify occupancy detection status and c...	Firestone	Firestone VAV-37
<input type="radio"/>	42	CX-F008 AHU-2 CD Branch duct static pressure present whe...	Firestone	Firestone AHU-2
<input type="radio"/>	43	INT-002 Sup Temp Sensor Fail Spark	Firestone	Firestone HWSys
<input type="radio"/>	44	CX-F011 VAV_187 Unoccupied Heating Setpoint 23F	Firestone	Firestone VAV-18
<input type="radio"/>	45	Firestone AHU-2 OSA Damper Stuck Open Spark	Firestone	Firestone AHU-2
<input type="radio"/>	46	Firestone AHU-2 HD	Firestone	Firestone AHU-2
<input type="radio"/>	47	CX-F005 VAV-275 Occupancy Detection Always Enabled (VA...	Firestone	Firestone VAV-27
<input type="radio"/>	48	CX-F012 AHU-2 HD Cold Startups	Firestone	Firestone AHU-2
<input type="radio"/>	49	CX-M002 Mead AHU-C1 CHW Valve Cycling (AHU-1)	Mead	Mead AHU-1
<input type="radio"/>	50	CX-F017 HW System supply temp sensor failure (HWSys)	Firestone	Firestone HWSys
<input type="radio"/>	51	CX-F002 AHU-2 Filter Pressure Drop	Firestone	Firestone AHU-2
<input type="radio"/>	52	Firestone AHU-2 Sparks Correction Request	Firestone	Firestone AHU-2
<input type="radio"/>	53	CX-F003 AHU-2 Cold Deck Static Pressure Reset Cycling (...)	Firestone	Firestone AHU-2
<input type="radio"/>	54	CX-F010 AHU-2 Bldg Static Pressure Sensor Inaccurate	Firestone	Firestone AHU-2
<input type="radio"/>	55	Firestone AHU-2 Schedule - Occupied on Weekend Days?	Firestone	Firestone AHU-2
<input checked="" type="radio"/>	56	CX-F016 AHU-2 Economizer Enable	Firestone	Firestone AHU-2
<input type="radio"/>	57	Test App Link	Firestone	
<input type="radio"/>	58	CX-F018 AHU-2 OSA Damper Min Position (AHU-2 CD)	Firestone	Firestone AHU-2
<input type="radio"/>	59	AHU-2 Firestone Return Fan Control	Firestone	Firestone AHU-2

Open Reply Reassign Close

#56: CX-F016 AHU-2 Economizer Enable

OPEN and assigned to **Jared Lee**

- **Site:** Firestone
- **Equip:** Firestone AHU-2
- **Details:** [Link \(Trends from 2017-02-08\)](#)

Issue Description: ISSUE: Economizer Enable OSA Temp Setpoint is set to 65degF. Per Design should be 80degF. Missing significant economizer opportunity otherwise. Also, per design, Economizer should enable/disable off of both return temp OR osa temp conditions.

REQUEST: Update economizer enable osa temp setpoint. Verify return temp condition is included in economizer osa enable/disable

Issue Comments:

■ (Feb-08-2017 4:30pm) su:


ISSUE: Economizer Enable OSA Temp Setpoint is set to 65degF. Per Design should be 80degF. Missing significant economizer opportunity otherwise. Also, per design, Economizer should enable/disable off of both return temp OR osa temp conditions.

REQUEST: Update economizer enable osa temp setpoint. Verify return temp condition is included in economizer osa enable/disable

And a work order is born



FIRESTN18093685		Created By On 03/15/2018 02:08 PM Last Edited by On 03/15/2018 02:08 PM		Status	OPEN
Identifies when the chw valve position cmd [ruleOnPosition] is open [config_Polarity] to a position tolerance of 2 [tune_PositionTol] while commanded the opposite. This is identified when the delta between the entering temperate mixed air temp [ruleOnSen				Project	
				Desired Date	
				Budget	
Organization		Region	010	Problem Code	SPARK-M0005
			PASADENA		AHU ECONOMIZER DISABLE FAIL
Requestor		Facility	011	Type	PLANNED
			CAMPUS		PLANNED MAINTENANCE
Contact		Property	050	Category	PREDICTIVE
Contact Phone			FIRESTONE LAB		SAME AS PREVENTIVE MAINTENANCE BUT WITH NO
Contact Email				Job Priority	

Haystack enabled API relationship Ex 3




Optimal Filter Maintenance

- The replacement of AHU filters is classic case of a labor and material-cost intensive PM. And with significant energy cost implications!!
- Determine the optimal time to change air filter based on minimizing total cost of ownership.



Optimal Filter Maintenance



Only requires 3 normalized data points to scale across all air handling units.


- Filter differential pressure – required
- Supply air flow – required (can be estimated)
- Supply fan power - optional



And a work order, again

FIRESTN18093685		Created By On 03/15/2018 02:08 PM Last Edited by On 03/15/2018 02:08 PM		Status OPEN	
Identifies when the chw valve position cmd [ruleOnPosition] is open [config_Polarity] to a position tolerance of 2 [tune_PositionTol] while commanded the opposite. This is identified when the delta between the entering temperate mixed air temp [ruleOnSen]				Project	
				Desired Date	
				Budget	
Organization		Region	010	Problem Code	SPARK-M0005
			PASADENA		AHU ECONOMIZER DISABLE FAIL
Requestor		Facility	011	Type	PLANNED
			CAMPUS		PLANNED MAINTENANCE
Contact		Property	050	Category	PREDICTIVE
Contact Phone			FIRESTONE LAB		SAME AS PREVENTIVE MAINTENANCE BUT WITH NO
Contact Email				Job Priority	

Haystack enabled API relationship Ex 4



What can you do with 25,000
Haystack tagged data points?


May 13-15, 2019







Haystack enabled API relationship Ex 5




Large Scale System Comparisons

Systems Reporting CHW Plant Metrics CHW Plant Snapshot Airside Metrics Airside Snapshot Opportunity Group Report Portfolio Opportunities Issue Log Project List



< Week of 28-Apr-2019 > Min / Max Off

KPI	Central CHW Plant	Central CHW Plant East	
Average Plant Delivery Efficiency (kW/ton)	0.655	1.08	1.4
Total Plant Electric Energy (kWh)	326,173	86,030	82
Total Plant Cooling Energy (tonrefh)	485,227	78,947	85
Average CHW Supply Temp (°F)	43.4	41.6	42
Average CHW Return Temp (°F)	52.5	49.9	49
Average CHW ΔT (°F)	9.13	8.38	7.1
Average CDW Supply Temp (°F)	60.4	74.0	73
Total Waterside HX Runtime (h)		1.75	0.5
Total HX Parallel Mode Runtime (h)			
Average Outside Air Temp (°F)	71.8	76.9	76
Average CHW Flow (gal/min)	7,574	2,287	1,7

Average CHW ΔT (°F) • Daily Average



Raw History Data & High Priority Sparks by System (Week of 28-Apr-2019)



“Tag in” Project Haystack

- Start with Haystack standards before tech commitments
- People matter and disclaimer: change management not included
- Bring a creative mind to problem solving